



NOTES:

- *SEE PLAN FOR LOCATIONS OF EXISTING FIXTURES TO REMAIN
- *PROVIDE GROUND ROD 3/4" X 8' AT EVERY OTHER POLE AND CONNECT TO GROUND LUGS IN POLE BASE & TO GROUND WIRE.

FOOTING NOTES:

1. FOOTING REBAR TO BE 4 #9 VERTICAL WITH #3 TIES, 12" O.C.
2. BOND GRS CONDUIT, ANCHOR BOLTS, GROUND WIRE AND GROUND ROD TO LIGHT GROUND LUGS.
3. FOOTING SHALL BE CAST-IN-PLACE; PRE-CAST IS NOT ACCEPTABLE
4. ALL REINFORCED CONCRETE CONSTRUCTION AND PLACEMENT SHALL BE IN ACCORDANCE WITH ACI-318 LATEST EDITION.
5. CONTRACTOR SHALL LOCATE ANCHOR BOLTS, CONDUITS, ETC. BASED ON MANUFACTURERS DATA FOR EQUIPMENT SUPPLIED.

DRAWN BY: TS

VEHICLE TRAFFIC AREA LIGHT POLE FOOTING

CHECKED BY: MG

PROJ #: -

DATE: 09-11-2000

DWG. # SK-12

THE STATE UNIVERSITY OF NEW JERSEY
RUTGERS

UNIVERSITY PLANNING AND DEVELOPMENT
PISCATAWAY, NEW JERSEY

SK-12