



NOTES:
 -TRACER WIRE MUST LAY FLAT AND STRAIGHT. NO COILS MAY BE PRESENT TO INSURE LINEAR RF RADIATION. BENDS, WAVES & COILS DISRUPT THE RF LOCATING PROCESS
 - ALL CONNECTIONS MUST BE SOLDERED AND WATERTIGHT -TAPE MUST NOT BE DAMAGED OR TORN
 -TRACER WIRE RUN MUST NOT EXCEED 300' WITHOUT ADDITIONAL TEST STATION

NOTES:
 -WATER MAIN 3" AND LARGER SHALL BE DUCTILE IRON CEMENT LINED, MECHANICAL JOINT WEDGE ACTION RETAINING GLANDS.
 -ALL FITTINGS SHALL BE MECHANICAL JOINT WITH WEDGE ACTION RETAINING GLANDS

- COVER EXTERIOR PIPES PER FACTORY MUTUAL REQUIREMENTS (OR MINIMUM 3'6")

DRAWN BY: TS
 CHECKED BY:
 SCALE: N.T.S.
 DATE: 04/25/2022

WATER LINE INSTALLATION DETAIL

RUTGERS
 THE STATE UNIVERSITY
 OF NEW JERSEY
 UNIVERSITY FACILITIES PISCATAWAY,
 NEW JERSEY

SK-46